

Consumers Energy Business Solutions Program

Everyone has the power to save.

Measure Specifications (2009 Program Year)

These specifications cover the measures that are available within the Consumers Energy Business Solutions Program. Please see the program application and policy and procedures manual for more details on the application process.

Table of Contents

Equipment Specifications.....	4
<i>LIGHTING</i>	4
Compact Fluorescent Lamps, Screw-In	4
Specialty Compact Fluorescent Lamps.....	4
Compact Fluorescent Fixtures	4
Standard Linear Fluorescent Retrofit	4
High Performance 4-foot T8 Lamp and Ballast	5
Reduced Wattage 4-foot T8 Lamp and Ballast	6
Reduced Wattage 4-foot T8 Lamps (Lamps Only).....	6
Permanent Lamp Removal (Pre-notification is required)	7
Exit Signs	8
LED Traffic and Pedestrian Lights	8
Lighting Controls	8
New T8/T5 Fluorescent Fixtures (Pre-notification is required).....	8
Examples of Common Lighting Retrofits	12
<i>HVAC (electric)</i>	12
Unitary and Split Air Conditioning Systems and Air Source Heat Pumps	12
Room Air Conditioners	13
Package Terminal AC and Heat Pump Units (PTAC/PTHP)	13
Ground-source Heat Pumps	13
Air- and Water-cooled Chillers	14
<i>GAS</i>	14
General Clause for Heating Measures	14
Steam Trap Survey and Repair/Replacement	14
High Efficiency Space Heating Boiler	15
Boiler Tune-up.....	16
Boiler Modulating Burner Control	16
Boiler Water Reset Control	17
Pipe Wrap – Steam Boiler	17
Condensing Furnace.....	17
Infrared Heaters	17
Programmable Thermostat	18
Guestroom Energy Management Control (Gas Heat).....	18
Water Heat Pipe Wrap – Hot Water Boiler.....	18
Pre-rinse Sprayers - < 1.6 gpm (Gas Water Heater).....	18
Gas Storage Water Heater.....	18

Gas Tankless Water Heater	19
High Efficiency Clothes Washer (Gas Water Heater)	19
High Efficiency Pool Heater	19
Pool Covers.....	19
<i>MOTORS & DRIVES</i>	19
NEMA Premium Motors	19
Variable Speed Drives on HVAC Fans and Pumps	20
<i>MISCELLANEOUS</i>	20
Beverage Vending Machine Controllers.....	20
Hotel HVAC Occupancy Sensor (Electric Heat).....	20
Intelligent Surge Protector.....	21
Energy Efficient Ice Makers	21
Pre-rinse Sprayers < 1.6 gpm with electric HW	21
Anti-sweat Heater Controls	21
Night Covers	21
Engineered Nozzle.....	22
High Efficiency Clothes Washer (Electric Water Heater)	22
<i>CUSTOM</i>	22
Custom Measures	22

EQUIPMENT SPECIFICATIONS

The following provides the equipment specifications for the measures eligible for incentives. Note: All equipment must be recycled/disposed of according to state, federal and local regulations. Information about the requirements for the state of Michigan can be found at the Michigan Department of Environmental Quality website: <http://www.michigan.gov/deq/>.

LIGHTING

Compact Fluorescent Lamps, Screw-In

Incentives are available to install screw-in CFLs that are ENERGY STAR® rated lamps or meet ENERGY STAR® criteria. The lamps must have ≥ 50 lumens per watt (LPW).

Specialty Compact Fluorescent Lamps

Incentives are available for replacing existing incandescent lamps, metal halide or induction lamps, or other non-CFL with Specialty CFLs (such as PAR, 3-way, dimmable). A Specialty CFL is one that is not non-dimmable, bare spiral, and/or not single wattage. The lamps must meet ENERGY STAR® criteria, if available for the type of lamp

Compact Fluorescent Fixtures

Incentives are available for interior hardwired compact fluorescent fixtures. Only complete new fixtures or modular hardwired retrofits with hardwired electronic ballasts qualify. The compact fluorescent ballast must be programmed start or programmed rapid start with a power factor (PF) ≥ 90 and a total harmonic distortion (THD) ≤ 20 percent.

Standard Linear Fluorescent Retrofit

Incentives are available for replacing existing T12 lamps and magnetic ballasts with T8 or T5 lamps and electronic ballasts. The new fixture lamps must have a color rendering index (CRI) ≥ 80 . The electronic ballast must be high frequency (≥ 20 kHz), UL listed, and warranted against defects for a minimum of 5 years. Ballasts must have a power factor (PF) ≥ 0.90 . Ballasts for 4-foot lamps must have total harmonic discharge (THD) ≤ 20 percent at full power output. For 2 and 3-foot lamps, ballasts must have THD ≤ 32 percent at full light output. A manufacturer's specification sheet must accompany the application.

High Performance 4-foot T8 Lamp and Ballast

Incentives are available for replacing existing T12 lamps and magnetic ballasts with high performance T8 lamps and electronic ballasts. This measure is based on the Consortium for Energy Efficiency (CEE) high performance T8 specification (www.cee1.org) and is summarized in Table 1. A list of qualified lamps and ballasts can be found at: <http://www.cee1.org/com/com-lt/com-lt-main.php3>. Both the lamp and ballast must meet the specification in order to qualify for an incentive. A manufacturer's specification sheet must accompany the application.

Table 1: High Performance T8 Specifications

High Performance T8 Characteristics					
Mean System Efficiency	≥ 90 Mean Lumens per Watt (MLPW) for Instant Start Ballasts				
	≥ 88 MLPW for Programmed Rapid Start Ballasts				
Performance Characteristics for Lamps					
Color Rendering Index (CRI)	≥ 80				
Minimum Initial Lamp Lumens	≥ 3100 Lumens ¹				
Lamp Life	≥ 24,000 Hours				
Lumen Maintenance or Minimum Mean Lumens	≥ 94% or ≥ 2900 Mean Lumens				
Performance Characteristics for Ballasts					
	Lamps	Low BF ≤ 0.85	Norm 0.85 < BF ≤ 1.0	High BF ≥ 1.01	
	Instant Start Ballast (BEF)				
	1	> 3.08	> 3.11	NA	
	2	> 1.60	> 1.58	> 1.55	
	3	≥ 1.04	≥ 1.05	≥ 1.04	
	4	≥ 0.79	≥ 0.80	≥ 0.77	
	Programmed Rapid Start Ballast (BEF)				
	1	≥ 2.84	≥ 2.84	NA	
	2	≥ 1.48	≥ 1.47	≥ 1.51	
	3	≥ 0.97	≥ 1.00	≥ 1.00	
	4	≥ 0.76	≥ 0.75	≥ 0.75	
	Ballast Frequency	20 to 33 kHz or ≥ 40 kHz			
	Power Factor	≥ 0.90			
	Total Harmonic Distortion	≤ 20%			

¹ For lamp with color temperatures ≥ 4500k. 2950 minimum initial lamp lumens are allowed.

Reduced Wattage 4-foot T8 Lamp and Ballast

Incentives are available for replacing T12 systems with reduced wattage lamp and electronic ballast systems. The lamps and ballasts must meet the Consortium for Energy Efficiency (CEE) specification (www.cee1.org) and summarized in Table 2. Qualified lamp and ballast products can be found at <http://www.cee1.org/com/com-lt/com-lt-main.php3>. Both the lamp and ballast must qualify in order to receive an incentive for the system. A manufacturer's specification sheet must accompany the application.

Reduced Wattage 4-foot T8 Lamps (Lamps Only)

Incentives are available when replacing 32 Watt T8 lamps with reduced wattage T8 lamps when an electronic ballast is already present. The lamps must be reduced wattage in accordance with the Consortium for Energy Efficiency (CEE) specification (www.cee1.org) and summarized in Table 2 below. Qualified products can be found at <http://www.cee1.org/com/com-lt/com-lt-main.php3>. The nominal wattage must be 28W (≥ 2585 Initial Lumens) or 25W (≥ 2400 Initial Lumens) to qualify.

Table 2: Reduced Wattage 4-foot Lamps and Ballasts

Performance Characteristics for Lamps ²		
Mean System Efficacy	≥ 90 MLPW	
Color Rendering Index (CRI)	≥ 80	
Minimum Initial Lamp Lumens	≥ 2585 Lumens for 28 W	
	≥ 2400 Lumens for 25 W	
Lamp Life ³	≥ 18,000 hrs at three hours per start	
Lumen Maintenance –or- Minimum Mean Lumens ⁴	≥ 94% -or-	
	≥ 2430 Lumens for 28 W	
	≥ 2256 Lumens for 25 W	
Performance Characteristics for 28 and 25 W Ballasts		
Ballast Frequency	20 to 33 Hz or ≥ 40 kHz	
Power Factor	≥ 0.90	
Total Harmonic Distortion	≤ 20%	
Performance Characteristics for Ballasts ⁵ , 28 W systems		
Ballast Efficiency Factor (BEF)	Instant Start Ballast (BEF)	
BEF = [BF x 100]/Ballast Input Watts Based on: (1) Type of ballast (2) No. of lamps driven by ballast (3) Ballast Factor	Lamps	All BEF Ranges
	1	≥ 3.52
	2	≥ 1.76
	3	≥ 1.16
	4	≥ 0.88
Performance Characteristics for Ballasts ⁶ , 25 W systems		
Ballast Efficiency Factor (BEF)	Instant Start Ballast (BEF)	
BEF = [BF x 100]/Ballast Input Watts Based on: (1) Type of ballast (2) No. of lamps driven by ballast (3) Ballast Factor	Lamps	All BEF Ranges
	1	≥ 3.95
	2	≥ 1.98
	3	≥ 1.32
	4	≥ 0.99

Permanent Lamp Removal (Pre-notification is required)

Incentives are paid for the permanent removal of existing fluorescent lamps. Permanent lamp removal is the net reduction in the quantity of lamps after a project is completed. Customers are

² Lamps ≥4500 K and/or 24,000 hours have a system efficiency specified ≥ 88 MLPW. Minimum initial and mean lumen levels are specified as follows: for 28 W lamps, limits are 2600/2340. For 25 W lamps, limits are 2300/2185.

³ Life rating is based on an instant Start Ballast tested in accordance with ANSI protocols. When used for Program Start Ballast, life may be increased depending upon the operating hours per start.

⁴ Mean lumens measures at 7,200 hours

⁵ Multi-Voltage Ballasts must meet or exceed the listed Ballast Efficiency Factor when operated on at least one of the intended operating voltages.

⁶ Multi-Voltage Ballasts must meet or exceed the listed Ballast Efficiency Factor when operated on at least one of the intended operating voltages.

responsible for determining whether or not to use reflectors in combination with lamp removal in order to maintain adequate lighting levels. Lighting retrofits are expected to meet the Illuminating Engineering Society of North America (IESNA) recommended light levels. Unused lamps, lamp holders, and ballasts must be permanently removed from the fixture and disposed of in accordance with local regulations. This measure is applicable when retrofitting from T12 lamps to T8 lamps only. Removing lamps from a T12 fixture that is not being retrofitted with T8 lamps are not eligible for this incentive.

Exit Signs

Incentives for high-efficiency exit signs are available and must replace or retrofit an existing incandescent exit sign. Electroluminescent, T1, and light-emitting diode (LED) exit signs are eligible under this category. Non-electrified and remote exit signs are not eligible. All new exit signs or retrofit exit signs must be UL or ETL listed, have a minimum lifetime of 10 years, and have an input wattage ≤ 5 Watts per face or be ENERGY STAR® qualified.

LED Traffic and Pedestrian Lights

Incentives are available for LED traffic lights on a per-signal basis (including arrows) that replace or retrofit an existing incandescent traffic signal. At minimum, red and green lamps must be retrofitted to qualify for the signal incentive. Signals shall have a maximum LED module wattage of 25. Incentives are not available for spare lights. Lights must be hardwired, with the exception of pedestrian hand signals.

Lighting Controls

Incentives for passive infrared, ultrasonic detectors and fixture-integrated sensors or sensors with a combination thereof are eligible. All sensors must be hard-wired and control interior lighting fixtures. To assist in rebate processing, please provide the inventory of the controlled fixtures with the Final Application.

New T8/T5 Fluorescent Fixtures (Pre-notification is required)

Incentives for this measure require replacing one or more existing fixtures with new fixtures containing T8 or T5 lamps and electronic ballasts. The T8 or T5 lamps must have a color rendering index (CRI) ≥ 80 . The electronic ballast must be high frequency (≥ 20 kHz), UL listed, and warranted against defects for 5 years. Ballasts must have a power factor (PF) ≥ 0.90 . Ballasts for 4-foot lamps must have total harmonic distortion (THD) ≤ 20 percent at full light output. For 2- and 3-foot lamps, ballasts must have THD ≤ 32 percent at full light output. High output T5/T8 lamps also qualify for this rebate. This incentive can be used in highbay and lowbay fluorescent applications. Specifications of the new fixtures, lamps and ballasts, must

accompany the final application. If specification sheets are not included, the default fixture wattages provided in the table below will be used instead. Incentives are only available for new fixtures. Retrofit kits are not considered to be new fixtures.

Table 3: Default Fixture Wattages (Standard Linear Fluorescent)

Fixture Description	Default Fixture Wattage
1-lamp, 4-foot F32 T8	31
2-lamp, 4-foot F32 T8	58
3-lamp, 4-foot F32 T8	83
4-lamp, 4-foot F32 T8	114
1-lamp, 8-foot F59 T8	68
2-lamp, 8-foot F59 T8	109
1-lamp, 2-foot F17 T8	18
2-lamp, 2-foot F17 T8	31
3-lamp, 2-foot F17 T8	45
4-lamp, 2-foot F17 T8	62
1-lamp, 3-foot F25 T8	24
2-lamp, 3-foot F25 T8	46
3-lamp, 3-foot F25 T8	62
4-lamp, 3-foot F25 T8	83
1-lamp, 4-foot F28 T5	31
2-lamp, 4-foot F28 T5	60
4-lamp, 4-foot F28 T5	120

Table 4: Default Fixture Wattages (High Output Linear Fluorescent)

Fixture Description	Default Fixture Wattage
1-lamp, 4-foot F32 T8 HO	36
2-lamp, 4-foot F32 T8 HO	72
3-lamp, 4-foot F32 T8 HO	92
4-lamp, 4-foot F32 T8 HO	120
1-lamp, 8-foot F59 T8 HO	71
2-lamp, 8-foot F59 T8 HO	118
2-lamp, 2-foot F17 T8 HO	32
3-lamp, 2-foot F17 T8 HO	48
1-lamp, 3-foot F25 T8 HO	30
2-lamp, 3-foot F25 T8 HO	47
3-lamp, 3-foot F25 T8 HO	68
4-lamp, 3-foot F25 T8 HO	90
6-lamp, 4-foot F32 T5 HO	224
3-lamp, 8-foot F59 T5 HO	191
4-lamp, 8-foot F59 T5 HO	236
1-lamp, 4-foot F54 T5 HO	59
4-lamp, 4-foot F54 T5 HO	234
6-lamp, 4-foot F54 T5 HO	351

Table 5: Default Fixture Wattages (Metal Halides and High Pressure Sodium)

Fixture Description	Default Fixture Wattage
32W Metal Halide	43
50W Metal Halide	61
70W Metal Halide	90
75W Metal Halide	95
100W Metal Halide	120
150W Metal Halide	167
175W Metal Halide	210
250W Metal Halide	290
300W Metal Halide	350
325W Metal Halide	375
360W Metal Halide	420
400W Metal Halide	455
750W Metal Halide	820
1000W Metal Halide	1090
1500W Metal Halide	1625
35W High Pressure Sodium	43
50W High Pressure Sodium	63
70W High Pressure Sodium	90
100W High Pressure Sodium	130
150W High Pressure Sodium	190
200W High Pressure Sodium	245
250W High Pressure Sodium	300
400W High Pressure Sodium	465

Examples of Common Lighting Retrofits

Examples of the incentives associated with common retrofits found in the commercial sector are shown in the tables below. In order to calculate the incentives for replacing metal halides with new T8 and T5 fixtures, the applicant must provide the wattage reduction from the retrofit.

Table 6: Metal Halide to New T8/T5 Common Retrofit Examples

Existing Measure	Retrofitted Measure	Wattage Reduction	Incentive
250W MH	3-lamp, 4-foot T5 HO	108	\$37.80
400W MH	4-lamp, 4-foot T5 HO	212	\$74.20
400W MH	6-lamp, 4-foot T5 HO	90	\$31.50
750W MH	8-lamp, 4-foot T5 HO	364	\$127.40
1000W MH	Two 6-lamp, 4-foot T5 HO	350	\$122.50
150-175W MH	3-lamp, 4-foot F32 T8	82	\$28.70
250W MH	4-lamp, 4-foot F32 T8	148	\$51.80
400W MH	6-lamp, 4-foot F32 T8	231	\$80.85
400W MH	8-lamp, 4-foot F32 T8	156	\$54.60
1000W MH	Two 8-lamp, 4-foot F32 T8	482	\$168.70

HVAC (ELECTRIC)***Unitary and Split Air Conditioning Systems and Air Source Heat Pumps***

New unitary air conditioning units or air source heat pumps that meet or exceed the qualifying cooling efficiencies shown in shown in the HVAC Electric Incentives Table are eligible for an incentive. They can be either split systems or single package units. The efficiency of split systems is based on an ARI reference number. Water-cooled systems, evaporative coolers, and water source heat pumps do not qualify under prescriptive, but may qualify for a custom incentive. All packaged and split system cooling equipment must meet Air Conditioning and Refrigeration Institute (ARI) standards (210/240, 320 or 340/360), be UL listed, and use a minimum ozone-depleting refrigerant (e.g., HCFC or HFC). All required efficiencies are based on the Consortium for Energy Efficiency (CEE) high efficiency commercial air conditioning and heat pump specifications (www.cee1.org). A manufacturer's specification sheet indicating the system efficiency must accompany the application. Disposal of the existing unit must comply with local codes and ordinances.

Room Air Conditioners

Incentives are available for room air conditioning units that are through-the-wall (or built-in) self-contained units that are 2 tons or less. There are two eligible efficiency levels as listed by the CEE (www.ceel.org). A unit must qualify under ENERGY STAR® standards. The minimum requirements and eligible equipment are listed in the CEE high efficiency room air conditioning specifications (www.cee1.org). These units are with and without louvered sides, without reverse cycle (i.e., heating), and casement. The qualifying efficiencies are provided in Table 7 below. Disposal of existing unit must comply with local codes and ordinances.

Table 7: Qualifying A/C efficiencies

Size (Btuh)	2000 ENERGY STAR® (EER)
< 8,000 (< 0.67 tons)	10.7
8,000 - 13,000 (0.57 - 1.2 tons)	10.8
14,000 - 19,999 (1.3 - 1.7 tons)	10.7
≥ 20,000 (>1.7 tons)	9.4

Package Terminal AC and Heat Pump Units (PTAC/PTHP)

Incentives are available for package terminal air conditioners and heat pumps that are through-the-wall self contained units that are 2 tons (24,000 Btuh) or less. Only units that have an EER greater than or equal to $11.99 - (0.234 * \text{Capacity} / 1000)$, where capacity is in Btuh, qualify for the incentive (10 percent above IECC 2006 Standard). All EER values must be rated at 95°F outdoor dry-bulb temperature.

Ground-source Heat Pumps

New ground source heat pumps that meet or exceed the qualifying Energy Efficiency Ratio (EER) as listed in the HVAC Incentive Worksheet Table are eligible for an incentive. Equipment with an EER equal to 17 receive a fixed rebate; equipment with an EER value greater than the qualifying value will be paid \$1.00 per 0.1 EER incremental increase. All equipment must meet Air Conditioning and Refrigeration Institute (ARI) standards (325 or 330) and be UL listed. EER is the efficiency at standard (ARI/ISO) conditions of 77°F entering water for closed-loop models and 59°F entering water for open-loop systems. A manufacturer's specification sheet indicating the system efficiency for cooling and heating must accompany the application. Disposal of the existing unit must comply with local codes and ordinances.

Air- and Water-cooled Chillers

Chillers are eligible for an incentive if they have a rated kW/ton for the Integrated Part Load Value (IPLV) and/or EER that is less than or equal to the qualifying Level 1 (10 percent below IECC 2006 standard) efficiency shown in the table below. The chiller efficiency rating must be based on ARI Standard 550/590-2003 for IPLV and/or based on full-load conditions. The chillers must meet ARI standards 550/590-2003, be UL listed, and use a minimum ozone-depleting refrigerant (e.g., HCFC or HFC). The ARI net capacity value should be used to determine the chiller tons. A manufacturer's specification sheet with the rated full load kW/Ton or COP and kW/Ton-IPLV or COP-IPLV must accompany the application. Qualifying efficiencies for chillers are summarized in Table 8 below. There is a fixed rebate for reaching the minimum qualifying efficiency, and incremental rebates for every 0.01 kW/ton-IPLV reduction from the minimum required.

Table 8: Water Cooled Qualifying Chiller Efficiencies (kW/ton)

Equipment Category	Capacity Range (Btu/hr)	IPLV	Full Load
Screw, Scroll, or Helical-Rotary	<150 tons	0.612	0.711
	150 – 300 ton	0.567	0.648
	> 300 ton	0.513	0.576
Centrifugal	<150 tons	0.603	0.630
	150 – 300 ton	0.540	0.567
	> 300 ton	0.495	0.522
Reciprocating	All	0.630	0.753

GAS

General Clause for Heating Measures

The incentive is eligible only for retrofit projects using natural gas as the primary fuel source. If a dual-fuel system is used, or if natural gas is the back-up or redundant fuel, the custom incentive application should be used. The incentives for boilers are only available for equipment used in space heating conditions, except for steam traps. Equipment for process load qualifies under the custom program.

Steam Trap Survey and Repair/Replacement

The customer may apply for the survey incentive, the repair incentive, or both. The **survey** incentive is available for all steam traps, functional, failed closed, or plugged. The **repair**

incentive is only available for repair or replacement of traps that have malfunctioned and **are leaking steam**. It is not available for traps which have failed closed or are plugged. The incentive is available once in a 24 month period per facility. Replacement with an orifice trap is not eligible for incentive. Steam trap survey and repair work must be recorded and attached to the incentive application by the vendor. A spreadsheet with survey/repair/replacement results must be provided. The spreadsheet at a minimum must contain:

- System nominal steam pressure
- Annual hours of operation
- Number of steam traps serviced
- Per steam trap:
 - ID tag number
 - Location type of trap
 - Type of trap
 - Orifice size (if repair or replaced)
 - Condition:
 - Functioning
 - Malfunctioning, not leaking steam
 - Malfunctioning, leaking steam
 - Survey/repair date
 - Survey/repair technician

High Efficiency Space Heating Boiler

Boiler incentives are only available for equipment used in space heating conditions. Equipment for process loads do not qualify. Boilers purchased for backup or redundancy are not eligible. Boilers must modulate their firing rate and have a sealed combustion unit. Applicant must submit boiler specifications with steady state boiler input and output ratings. The ratings will be defined per ANSI Standard Z21.13 and use supply and return water temperatures. Note that high efficiency condensing boilers will provide the rated efficiency only if return water is cold enough to condense the flue gases. If the heating system cannot meet the requirement, a non-condensing boiler may be a better choice. Qualifying efficiencies are shown in Table 9 below.

Table 9: Minimum Efficiency Requirements for High Efficiency Space Heating Boilers

Input Rating (Btuh)	Minimum Efficiency
< 300,000	0.88 AFUE
≥ 300,000	88% Combustion Efficiency

Boiler Tune-up

This incentive is only available for natural gas space-heating boilers. The minimum burner size for measure eligibility is 110,000 Btuh. The incentive is available once in a 24 month period. The service provider must perform before and after combustion efficiency tests and record the results on the boiler tune-up incentive application. Burner must be adjusted to improve combustion efficiency as needed. The incentives are only available for equipment used in space heating conditions. Equipment for process load does not qualify. Please provide a document with the following information:

- Boiler annual hours of operation
- Technician performing tune-up
- The contractor or technician performing the tune-ups needs to initial that each requirement listed below has been completed to qualify for the rebate:
 - Measure pre and post combustion efficiency using an electronic flue gas analyzer.
 - Include a copy of the combustion analyzer test
 - Adjust air flow and reduce excessive stack temperatures
 - Adjust burner and gas input, manual or motorized draft control
 - Clean burners, combustion chamber and heat exchange surface, when weather or operating schedule permits
 - Seal combustion chamber
 - Clean and inspect burner nozzles
 - Check for proper venting
 - Complete visual inspection of system piping and installation
 - Check safety controls
 - Check adequacy of combustion air intake
 - Provide the following data:
 - Date of tune-up
 - Unit Input capacity (MBtuh)
 - Boiler information(location, make & model #)
 - Type (hot water, low pressure steam, high pressure steam)
 - Combustion efficiency (pre and post)
 - Stack temperature (pre and post)
 - Oxygen level (pre and post)
 - Carbon dioxide (pre and post)
 - Carbon monoxide (pre and post)

Boiler Modulating Burner Control

Incentives are available for boiler modulating burner controls. The control must have a minimum of 5 to 1 or 10 to 1 turn-down ratio. Boiler must operate a minimum of 4000 hours per year to be eligible for this incentive. The incentive is eligible only for retrofit projects, not for new controls on a new boiler. The incentives are only available for equipment used in space heating conditions.

Boiler Water Reset Control

Incentives are available for boiler water reset controls. Outside air temperature reset or cutout control incentives are for existing space heating boilers only. A new boiler with boiler reset controls is not eligible. The system must be set so that the minimum temperature is not more than 10 degrees above manufacturer's recommended minimum return temperature. For controls on multiple boilers to qualify, control strategy must stage the lag boiler(s) only after the first boiler stage(s) fail to maintain the boiler water temperature called for by the reset control.

Pipe Wrap – Steam Boiler

Incentives are available for pipe wrap on a steam boiler. A minimum of 1 inch of R-4 pipe insulation must be added to existing bare commercial or industrial steel pipe system applications. The bare pipe size must be at least ½ inch or larger. A minimum of 10 linear feet of pipe must be insulated. Insulation used for pipes should be high density fiberglass shaped for pipes and blankets, batts of fiberglass or mineral wool for flat sections. Applications must include the manufacturer's name, insulation material type, and the material k-value or R-value rating. All hot surfaces should be insulated.

Condensing Furnace

Incentives are available condensing furnaces. Furnaces must be 92 percent AFUE or greater and have a sealed combustion unit. Furnaces must vary output by using a variable speed blower motor (ECM or brushless DC) and have at least two firing stages. Two-speed or multi-speed motors are not permitted. Air handlers are not eligible for the incentive. Chimney liners must be installed where a high efficiency natural gas furnace replaces atmospherically drafted equipment that was vented through the same flue as a gas water heater. Flue closure protocol must be used when a high efficiency furnace is installed and the chimney is no longer in use. The incentives are only available for equipment used in space heating conditions. Equipment purchased for backup or redundancy is not eligible. Rooftop units also qualify. Incentives are \$350 per unit up to 200 kBtuh, and incrementally at \$1.75 per kBtuh for units greater than 200 kBtuh.

Infrared Heaters

Only building space heating applications are eligible for this incentive. High-intensity and low-intensity heaters are eligible. Low-intensity heaters must use outside non-conditioned air for combustion. Heaters must have electronic ignition.

Programmable Thermostat

Incentives are available for programmable thermostats. Programmable thermostats must meet ENERGY STAR® criteria and must replace any non-programmable thermostat to automatically adjust the temperature at pre-selected times. To meet ENERGY STAR® standards, they must be capable of maintaining two separate programs (to address the different comfort needs of weekdays and weekends) and up to four temperature settings for each program. A current list may be found at

http://downloads.energystar.gov/bi/qplist/prog_thermostat_prod_list.pdf.

Guestroom Energy Management Control (Gas Heat)

Incentives are available for sensors that control PTAC, heat pump, and other HVAC units for individual hotel rooms. Sensors controlled by a front desk system are not eligible. Sensors must be controlled by automatic occupancy detectors, and it is recommended that during unoccupied periods, the default setting for controlled units differ by at least 8 degrees from the operating set point. The incentive is per guest room controlled, not per sensor; for multi-room suites the incentive is available per room controlled, if a sensor is installed in each room. Replacement or upgrades of existing occupancy-based controls are not eligible as a prescriptive incentive.

Water Heat Pipe Wrap – Hot Water Boiler

To qualify for this incentive, a minimum of 1 inch of R-4 pipe insulation must be added to existing bare commercial or industrial steel pipe system applications. The bare pipe size must be at least ½ inch or larger. A minimum of 10 linear feet of pipe must be insulated. Insulation used for pipes should be high density fiberglass shaped for pipes and blankets, batts of fiberglass or mineral wool for flat sections. Applications must include the manufacturer's name, insulation material type, and the material k-value or R-value rating. All hot surfaces should be insulated.

Pre-rinse Sprayers - < 1.6 gpm (Gas Water Heater)

To qualify for this incentive, the low-flow, high efficiency pre-rinse sprayer must be less than or equal to 1.6 gallons per minute (gpm) must replace a sprayer of 2.2 gpm or greater. Most installed sprayers are 2.5 gpm or greater. Customer must be a gas customer of the utility, and use gas fueled water heating.

Gas Storage Water Heater

To qualify for this incentive, the heater must replace existing natural gas water heater that meets the criteria in Table 10 shown below.

Table 10: Minimum efficiency requirements for gas storage water heaters.

Size (Gallons)	Minimum Efficiency
≤80	0.62 Energy Factor
>80	88% Thermal Efficiency

Gas Tankless Water Heater

To qualify for this incentive, the heater must replace existing natural gas water heater. Unit must be power vented with an Energy Factor of 0.82 or greater.

High Efficiency Clothes Washer (Gas Water Heater)

Incentives are available for high efficiency clothes washers that use a gas water heater. The high efficiency clothes washers wash more clothes than standard clothes washers that are DOE 2007 compliant while using less water and energy. The annual cycles per washer per year is assumed to be 950 cycles for commercial high efficiency clothes washers. Qualified clothes washers must meet a minimum efficiency of CEE Tier 2, with a Modified Energy Factor (MEF) \geq 2.00 and a Water Factor (WF) \leq 6.00.

High Efficiency Pool Heater

Incentives are available for high efficiency pool heaters. Heater must be equal to or greater than 84 percent thermal efficiency and must replace pre-existing pool heater. Heater must be rated between 500,000 Btuh and 2,000,000 Btuh. Must have an on/off switch and have no pilot light. The pool heater cannot be used as a back-up for solar water-heating.

Pool Covers

To qualify for this incentive, the pool size must be between 400 – 4,000 square feet to qualify for the incentive. Equipment must be new, and the cover must be a manual, semi-automatic or automatic pool cover.

MOTORS & DRIVES***NEMA Premium Motors***

Motors eligible for an incentive are three-phase AC induction motors, 1-250 HP, of open drip-proof (open) and totally enclosed fan-cooled (closed) classifications. Rewound motors do not qualify. Incentives are based on the motor's Nominal Full Load Efficiencies, tested in accordance with IEEE (Institute of Electrical and Electronics Engineers) Standard 112, method

B, that meet or exceed the NEMA Premium efficiency standards on the Motor Incentives Worksheet. The application must include the manufacturer's performance data sheet that at least shows equipment type, equipment size, model number, and efficiency rating. Customers should consider matching RPMs of the existing pump or fan when installing energy efficient motors that inherently have higher speeds (less slip), which may affect electric energy use.

Program incentives for this measure are available until new federal standards take effect which is scheduled to occur late in 2010. Per new federal efficiency standards enacted in H.R. 6, all general purpose motors (subtype I) manufactured after the standard change, with a power rating between 1 and 200 horsepower are required to have nominal full-load efficiencies equal to or greater than the NEMA MG- 1 (2006) (aka "NEMA Premium®" efficiency) levels.

Variable Speed Drives on HVAC Fans and Pumps

Variable-speed drives (VSDs) installed on existing HVAC fans and pumps are eligible for this incentive. New chillers with integrated VSDs are eligible under the chiller incentive, and installing VSDs on existing chillers and package unit compressors may be eligible under the custom incentive. VSDs on new equipment are not eligible. The installation of a VSD must accompany the permanent removal or disabling of any throttling devices such as inlet vanes, bypass dampers, and throttling valves. VSDs for non-HVAC applications may be eligible for a custom incentive, which include process motors, chillers, and air compressors. The incentive is per controlled HP.

MISCELLANEOUS

Beverage Vending Machine Controllers

Incentives are available for certain beverage vending machine controllers. The controller must include a passive infrared occupancy sensor to turn off fluorescent lights and other vending machine systems when the surrounding area is unoccupied for 15 minutes or longer. Also, the control logic should power up the machine at a minimum of every 2 hours to maintain product temperature and provide compressor protection. For refrigerated beverage machines located indoors, backlighting lamps and ballasts should be removed to obtain additional energy savings.

Hotel HVAC Occupancy Sensor (Electric Heat)

Incentives are available for sensors that control PTAC, heat pump, and other HVAC units for individual hotel rooms. Sensors controlled by a front desk system are not eligible. Sensors must be controlled by automatic occupancy detectors, and it is recommended that during unoccupied periods, the default setting for controlled units differ by at least 8 degrees from the operating setpoint. The incentive is per guest room controlled, not per sensor; for multi-room suites the

incentive is available per room controlled, if a sensor is installed in each room. Replacement or upgrades of existing occupancy-based controls are not eligible as a prescriptive incentive.

Intelligent Surge Protector

Incentives are available for surge protectors with built-in plug-load detection and control capabilities. The intelligent surge protector (“power strip”) must include at least one uncontrolled socket which a primary device would be connected to. Turning the primary device (usually a computer) on or off will subsequently turn the associated controlled devices in the power strip on or off (ex. printers, monitors, etc.). The intelligent power strip may also contain sockets for devices that require a constant supply of power; these will not be affected by the control device.

Energy Efficient Ice Makers

The incentive offering covers ice machines that generate 60 grams (2 oz.) or lighter ice cubes, flaked, crushed, or fragmented ice. Only air-cooled machines qualify (self-contained, ice-making heads, or remote condensing). The machine must have a minimum capacity of 101 lbs of ice per 24-hour period. The minimum efficiency required is per ENERGY STAR® or CEE Tier 2 (www.cee1.org). A manufacturer's specification sheet must accompany the application shows rating in accordance with ARI Standard 810.

Pre-rinse Sprayers < 1.6 gpm with electric HW

To qualify for this incentive, a low-flow, high efficiency pre-rinse sprayer less than or equal to 1.6 gallons per minute (gpm) must replace a sprayer of 2.2 gpm or greater. Most installed sprayers are 2.5 gpm or greater. Customer must be an electric customer of the utility, and use electric hot water heating.

Anti-sweat Heater Controls

Incentives are available for anti-sweat heater controls. To qualify for this incentive, a control device is installed that senses the relative humidity in the air outside of the display case and reduces or turns off the glass door (if applicable) and frame anti-sweat heaters at low-humidity conditions. Technologies that can turn off anti-sweat heaters based on sensing condensation (on the inner glass pane) also qualify. The incentive is based on the total number of doors controlled on the case.

Night Covers

Incentives are available for night covers installed on open refrigerated display cases in supermarkets and grocery stores. The purpose of night covers is to reduce the amount of heat loss from the open refrigerated display cases during facility non-operating hours. The store must

have a minimum of 6 non-operating hours per day for this measure to qualify. To decrease moisture build-up, it is recommended that the night covers are perforated. Applicant should consider using proper compressor capacity modulation and ensure the case manufacturer has no objections to use of a night cover.

Engineered Nozzle

Incentives are available for engineered nozzles that replace simple open pipe/tube assemblies connected to a compressed air system. Usage of the nozzles must be 2000 hours or greater per year. The Engineered nozzles must be between 1/8" and 1/2" in diameter. Air jets and nozzles must have an SCFM rating at 80 psig less than or equal to those rated in Table 11 below.

Table 11: Qualifying SCFM ratings for compressed air engineered nozzles.

Size (inch)	SCFM
1/8	10
1/4	17
3/8	18
1/2	18

High Efficiency Clothes Washer (Electric Water Heater)

Incentives are available for high efficiency clothes washers that wash more clothes than standard clothes washers that are DOE 2007 compliant while using less water and energy. Qualified clothes washers must meet a minimum efficiency of CEE Tier 2, with a Modified Energy Factor (MEF) ≥ 2.00 and a Water Factor (WF) ≤ 6.00 .

CUSTOM

Custom Measures

The Business Solutions Program staff will review each custom application. These measures will be reviewed based on (but not limited to) the following criteria: energy savings, verifiability, cost, measure life, and payback period. Applicants must provide the calculations documenting the estimated electrical energy (kWh and/or MCF) savings. The calculations, assumptions supporting the kWh and/or MCF impact estimates and the resulting incentive amount are subject to the Business Solutions Program staff review and approval.

Pre-notification is required for all custom incentive applications. The pre-notification step provides an assurance that the methodology meets the program requirements. The Applicant must provide sufficient information and calculations to estimate the energy impacts. Business Solution Program staff engineers will work with customers, their installing contractor or consultant to review the proposed savings methodology and to identify the information necessary to support the savings estimate and to collect any additional data needed to verify the savings.

Measurement and verification activities, including power measurements or monitoring for a period of time prior to and after the measure is installed may be required to document that energy impacts are consistent with the pre-approved estimates. In some cases, Consumers Energy may monitor the energy use of the base case (pre-retrofit) system as well as the post-retrofit system in order to establish the pre- retrofit energy and demand requirements. See the Business Solutions Program Custom Application and Policy and Procedures Manual for more details.

The final incentive amount will be based on the final savings documented through the Final Application and may include post-retrofit measurement review. This may be greater or less than the savings and/or incentive amount originally estimated in the pre-notification estimate, and may also be limited by fund availability.